

## 試驗報告



報告編號：TV-23-02147

頁數：1 OF 2

報告日期：112 年 07 月 04 日

昕澄國際有限公司  
台中市南屯區文心路一段 324 號 11F 之 1

產	品	名	稱：	PPR 水管
產	品	型	號：	SDR11
產	品	顏	色：	藍
製	造	廠	商：	Polymelt
供	應	廠	商：	昕澄國際有限公司
送	驗	廠	商：	昕澄國際有限公司
收	件	日	期：	112 年 06 月 05 日
試	驗	日	期：	112 年 06 月 05 日~112 年 07 月 04 日
備		註：	1.以上資料(送驗廠商、收件日期及試驗日期除外)及 下述報告內容標示#處係由顧客提供 2.除非另有說明，此報告結果僅對測試之樣品負責 未經本公司事先書面同意，此報告不可部分複製	

### 試驗要求：

#### 爆破水壓試驗

### #試驗方法：

將樣品接管連結水壓試驗機壓力後，先行開啟水壓機，讓其水流注滿測試件(管)，  
滿水後關閉，形成一密閉狀態，開始進行壓力試驗，升壓速率為 15kgf/cm<sup>2</sup>/分鐘，直到  
測試件達到破壞，其記錄試驗壓力之最大值。

### 試驗結果：

- 請詳附件 -

---1---

本報告若有提供規範值時，該規範值僅供參考，合格之判定以委託單位實際要求為準。

報告簽署人

This document is issued by the Company subject to its General Conditions of Service printed overleaf, available on request or accessible at <http://www.sgs.com.tw/Terms-and-Conditions> and, for electronic format documents, subject to Terms and Conditions for Electronic Documents at <http://www.sgs.com.tw/Terms-and-Conditions>. Attention is drawn to the limitation of liability, indemnification and jurisdiction issues defined therein. Any holder of this document is advised that information contained hereon reflects the Company's findings at the time of its intervention only and within the limits of Client's instructions, if any. The Company's sole responsibility is to its Client and this document does not exonerate parties to a transaction from exercising all their rights and obligations under the transaction documents. This document cannot be reproduced except in full, without prior written approval of the Company. Any unauthorized alteration, forgery or falsification of the content or appearance of this document is unlawful and offenders may be prosecuted to the fullest extent of the law. Unless otherwise stated the results shown in this test report refer only to the sample(s) tested.

## 試驗報告



報告編號：TV-23-02147

頁數：2 OF 2

報告日期：112 年 07 月 04 日

## 試驗設備：

儀器名稱	廠牌	型號
水壓試驗機	H.J.M	TV-094

## 試驗結果：

試驗項目	試驗結果
爆破水壓壓力(kgf/cm <sup>2</sup> )	62.7

註：1.本試驗報告之試驗地點同實驗室地址

2.樣品描述:同產品名稱

3.試驗時溫度：23℃

4.試驗報告 TV-23-02147 與 TV-23-02399 為同一委託案件，試驗報告 TV-23-02147 收件日期為 112 年 06 月 05 日

## 試驗照片：



試驗後



破裂狀態

- - -oOo- - -

本報告若有提供規範值時，該規範值僅供參考，合格之判定以委託單位實際要求為準。

This document is issued by the Company subject to its General Conditions of Service printed overleaf, available on request or accessible at <http://www.sgs.com.tw/Terms-and-Conditions> and, for electronic format documents, subject to Terms and Conditions for Electronic Documents at <http://www.sgs.com.tw/Terms-and-Conditions>. Attention is drawn to the limitation of liability, indemnification and jurisdiction issues defined therein. Any holder of this document is advised that information contained hereon reflects the Company's findings at the time of its intervention only and within the limits of Client's instructions, if any. The Company's sole responsibility is to its Client and this document does not exonerate parties to a transaction from exercising all their rights and obligations under the transaction documents. This document cannot be reproduced except in full, without prior written approval of the Company. Any unauthorized alteration, forgery or falsification of the content or appearance of this document is unlawful and offenders may be prosecuted to the fullest extent of the law. Unless otherwise stated the results shown in this test report refer only to the sample(s) tested.